

**Georgia Department of Human Resources  
PUBLIC SWIMMING POOL INSPECTION RECORD**

Name of Facility <u>Central Ymca</u>	Address <u>118 E 11th St</u>	City <u>Atlanta</u>	County <u>DeKalb</u>
Certified Pool Operator	Address	City	County

**SATISFACTORY**

**UNSATISFACTORY**

Deficiencies found on the inspection are marked with a (X). A check mark (✓) indicates satisfactory compliance, (NA) means non-applicable, \*Indicates a substantial health hazard. Other items may be considered substantial health hazards depending on severity. The pool must be closed until substantial health hazards are corrected. One or more substantial health hazards violated, two or more other items violated or repeated violations will result in an unsatisfactory rating. An unsatisfactory rating may result in enforcement action.

		X/✓	Notes:
POOL WATER  <u>89,200</u>	1. Water supply approved, adequate	✓	
	2. Depth properly marked	✓	
	3. Overflow facilities adequate	✓	
	4. Constant water level	✓	
	5. Turnover adequate	✓	
	* 6. Disinfectant residual: Concentration	✓	4.0
	* 7. pH (7.2-7.8)	✓	7.8
	8. Total Alkalinity	✓	
	9. Calcium Hardness	✓	
	10. Cyanuric Acid	na	
	*11. Clarity	na	
PUMPING FILTRATION AND TREATMENT SYSTEM	*12. Pump operating properly	✓	
	*13. Filters functioning properly	✓	
	14. Hair & lint strainers functioning properly	✓	
	*15. Skimmers/Gutters maintained & operating properly	✓	
	*16. Chemical feeders operating properly	✓	
DECK AND POOL AREA	17. Recirculation and filtration equipment readily accessible	✓	
	18. Pool & Decks clean, and in good repair	✓	
WATER AND FACILITIES	19. Night lighting adequate	✓	
	20. Hot & cold water under pressure	✓	
SEWAGE DISPOSAL	21. Adequate toilet facilities & showers	✓	
	22. Sewage disposal method: 1. Public, 2. Septic Tank, 3. Positive outlet, (approved and functioning properly)	1	
SAFETY PRE-CAUTIONS	23. Life line in place/Separation of wading pool	✓	
	24. Warning/Safety sign posted in clearview of pool area	✓	
	25. First aid kits available & properly equipped	✓	
	26. Emergency & lifesaving equipment in conspicuous place	✓	
	27. Emergency phone provided and hard wired	✓	
	28. Gas cylinder precautions adequate	na	
	29. Proper barrier around pool	✓	
	30. Main drains properly covered and maintained	✓	Letter on file
OPERATOR AND RECORDS	31. Certified Pool Operator: 1. On-site 2. Contract	1	
	32. Lifeguard(s) (if provided) has proper certification	✓	
	33. Trained operator on duty	✓	
	34. Appropriate records on file	✓	
	35. Pool test kit(s) available and adequate for all necessary tests	✓	
	36. Other <u>Water Foun.</u>	✓	

**ENFORCEMENT**

None

Permit Suspended

Closed Voluntarily

Re-inspection needed within \_\_\_\_\_ days

Hearing Requested/Recommended

Permit No.


Expiration Date

09	12	31	
YR	MO	DA	

Purpose:

1. Routine

2. Follow-up

3. Request

4. Complaint

5. Other \_\_\_\_\_

Length of Inspection 45 Minutes

Pool Type:

Swimming/Pool

Spa

Special Purpose Pool:

Type: Ymca

Required Turnover Rate 125 gpm

Type of Disinfectant HC

Required Concentration 1.5-5.0

Bather Load


Laboratory Sample

1. None

2. Water

3. Other

Reason for Sample:

Remarks: Pool Looks Fine, continue to clean, check tiles, replace as needed.

Replace kit as needed.

Date of Inspection <u>10/21/09</u>	Discussed with (Signature & Title) <u>[Signature]</u>	Inspected by (Signature & Title) <u>Nathy McCarley Tech</u>
---------------------------------------	--	--