

**Georgia Department of Public Health
PUBLIC SWIMMING POOL INSPECTION RECORD**

Name of Facility Holiday Inn North Pool		Address 2800 Manchester EXPY	City COLUMBUS	County
Certified Pool Operator Sam Pate		Address 10800 Wilshire BLVD	City LOS ANGELES	County
Deficiencies found on the inspection are marked with a (X). A check mark (✓) indicates satisfactory compliance, and (N/A) means non-applicable. *Indicates a substantial health hazard. Other items may be considered substantial health hazards depending on severity. The pool must be closed until substantial health hazards are corrected. One or more substantial health hazards violated, two or more other items violated or repeated violations will result in an unsatisfactory rating. An unsatisfactory rating may result in enforcement action.				
		X/✓	Notes	
POOL WATER	1. Water supply approved, adequate	✓		
	2. Depth properly marked	✓		
	3. Overflow facilities adequate	✓		
	4. Constant water level	✓		
	5. Turnover adequate	✓	(see addendum)	
	6. Disinfectant residual concentration 9.0	✓	(see addendum)	
	7. pH (7.2-7.8)	✓	(see addendum)	
	8. Total Alkalinity	✓	(see addendum)	
	9. Calcium Hardness	✓	(see addendum)	
	10. Cyanuric Acid	✓	(see addendum)	
	11. Clarity	✓		
PUMPING FILTRATION AND TREATMENT SYSTEM	12. Pump operating properly	✓		
	13. Filters functioning properly	✓		
	14. Hair & lint strainers functioning properly	✓		
	15. Skimmers/Gutters maintained & operating properly	✓		
	16. Chemical feeders operating properly	✓		
	17. Recirculation and filtration equipment readily accessible	✓		
DECK AND POOL AREA	18. Pool & Decks clean and in good repair	✓		
	19. Night lighting adequate	✓	(see addendum)	
WATER AND FACILITIES	20. Hot & cold water under pressure	✓	(see addendum)	
	21. Adequate toilet facilities & showers	✓		
SEWAGE DISPOSAL	22. Sewage disposal method: Public	✓		
SAFETY PRE-CAUTIONS	23. Life line in place/Separation of wading pool	✓		
	24. Warning/Safety sign posted in clearview of pool area	✓		
	25. First aid kits available & properly equipped	✓	(see addendum)	
	26. Emergency & lifesaving equipment in conspicuous place	✓		
	27. Emergency phone provided and hard wired	X	(see addendum)	
	28. Gas cylinder precautions adequate	✓	(see addendum)	
	29. Proper barrier around pool	✓		
	30. Main drains properly covered and maintained	✓		
OPERATOR AND RECORDS	31. Certified Pool Operator		(see addendum)	
	32. Lifeguard(s) (if provided) has proper certification	✓	(see addendum)	
	33. Trained operator on duty	✓	(see addendum)	
	34. Appropriate records on file	✓		
	35. Pool test kit(s) available and adequate for all necessary tests	✓		
	36. Other	✓	(see addendum)	
Remarks				
Date of Inspection 03/27/2012		Discussed with (Signature & Title) Chief Engineer		Inspected by (Signature & Title) Environmental Health Specialist III

SATISFACTORY

UNSATISFACTORY

ENFORCEMENT

None

Permit Suspended

Closed Voluntarily

Re-inspection needed within days

Hearing Requested/Recommended

Permit No.
SPP-106-000003

Expiration Date

2013	12	31
YY	MM	DD

Purpose:

3

1. Routine
2. Follow-up
3. Request
4. Complaint
5.

Other _____

Length of Inspection
732 Minutes

Pool Type:

Swimming/Pool

Spa

Special Purpose

Pool: Activity/Interactive/Wading
Type: Pool

Required Turnover Rate 85.00 hours

Type of Disinfectant trichlor

Required Concentration 3.0

Bather Load

7	4
---	---

Laboratory Sample

1

1. None
2. Water
3. Other

Reason for Sample:

**MUSCOGEE COUNTY HEALTH DEPARTMENT
 ENVIRONMENTAL HEALTH SECTION
 PUBLIC SWIMMING POOL INSPECTION RECORD ADDENDUM**

Name of Facility Holiday Inn North Pool	Address 2800 Manchester EXPY	City COLUMBUS	County
Operator Sam Pate	Address 10800 Wilshire BLVD	City LOS ANGELES	County

Item Number	Notes
5	90 gpm
6	9.0
7	7.2
8	90
9	NA
10	NA
19	Pool Hours 10am-10pm
20	Available in adjacent hotel rooms
25	Located in maintenance room
27	Phone not working.
28	NA
31	Sam Pate
32	NA
33	Paul Whitalowsky
36	water fountain available