

**Georgia Department of Public Health
TOURIST ACCOMMODATION INSPECTION RECORD**

Name of Accommodation		Address	City	County		
Microtel		1728 Fountain CT	COLUMBUS	Muscogee		
Deficiencies found during inspection are marked with an (X). A check mark (✓) indicates satisfactory compliance. (NA) means non-applicable.						
	No.	Item Description	Eval. Pts.	X ✓ NA	Notes	County 106 Permit No. TAP-106-000007 No. of Units 56 Purpose 9 1. Routine 2. Follow up 3. Request 4. Complaint 9. Other Inspection Time 13:40 Evaluation Points 96 Disposition 1 1. Permit Issued 2. Permit Denied 3. Enforcement Action Recommended
WATER SUPPLY	1.	Adequate, approved, no cross-connection	6	✓	(See addendum)	
	2.	Trailer water tank hose properly used & stored	1	✓	(See addendum)	
	3.	Cups, glasses & multiuse utensils washed, rinsed & sanitized after each occupancy or single service provided	4	X	(See addendum)	
	4.	Drinking founts of approved design	1	✓		
	5.	Ice from an approved source stored and handled properly	2	✓		
TOILET FACILITIES	6.	Toilet facilities provided	5	✓		
	7.	Rooms, fixtures clean & in good repair	2	✓		
	8.	Well lighted, ventilated	2	✓		
	9.	Hot & cold water under pressure, soap & individual towels, receptacles	2	✓		
	10.	Central toilet facilities, separate for each sex, provided within 200 feet of each dwelling unit served	3	✓	(See addendum)	
SEWERS	11.	Sewers & connections approved	2	✓	(See addendum)	
SEWAGE DISPOSAL	Method: Public Sewer			§		
	12.	Sewage & other liquid waste disposed of by an approved manner	4	✓		
PLUMBING	13.	Plumbing properly installed with no back siphonage, good repair	4	✓		
REFUSE DISPOSAL	14.	Containers adequate, approved, properly located	4	✓		
	15.	Approved collection & disposal	4	✓	(See addendum)	
INSECT / RODENT CONTROL	16.	Dwelling units effectively screened or other means for excluding vermin	2	✓		
	17.	Vermin effectively controlled	2	✓	(See addendum)	
HOUSING	18.	Clean, structurally sound, good repair	5	✓		
	19.	Well lighted, ventilated	1	✓		
	20.	Furnishings clean & in good repair	4	✓		
	21.	Bed clothing clean, linens replaced daily unless written notice is given to occupant	4	✓		
HEATING AND FIRE SAFETY	Type: Central Other			§		
	22.	All gas appliances properly vented to...?	6	✓		
	23.	Natural gas equipment equipped with automatic safety pilot, liquefied petroleum appliances with 100% safety pilot	6	✓		
	24.	Gas water heaters properly located and vented	1	✓		
	25.	Smoke detectors & fire extinguishers installed & operational	2	✓		
FOOD SERVICE	Type: Continental breakfast only			§		
	26.	In compliance with applicable rules	8	✓		
LAUNDRY ROOMS	27.	Separate, structurally sound, clean, good repair	2	✓		
	28.	Hot & cold water under pressure, adequate light & ventilation	2	✓		
GROUNDS	29.	Well drained, clean, maintained	1	✓		
	30.	Trailers properly spaced and marked 15 feet between trailers & property lines, 10 feet between trailers and internal driveways, abuts on drives 20 feet or wider	1	✓	(See addendum)	
	31.	Grounded & weatherproof electrical outlets at each trailer space; power lines underground or suspended or at least 18 feet above ground	1	✓	(See addendum)	
	32.	Swimming pool and spa in compliance	1	✓	(See addendum)	
EMPLOYEE HYGEINE	33.	Good personal hygiene, no communicable disease	4	✓		
PERMIT	34.	Permit displayed, current inspection report posted	1	✓		
Additional comments: * Place Appropriate Number in Block Also single use coffee stirrers must be wrapped or properly dispensed. It was agreed upon by Rinkesh Patel on 4/11/12 that a 3 compartment sink along with the two compartment sink (with installed splash guard) will be installed. The kitchen/prep area will be located on the 2nd floor where there is already a employee bathroom and a refrigerator and cooler located. Fruit is being served at this hotel. Multiuse coffee pots are located in some of the rooms. These items must be properly washed, rinsed, and sanitized.						
Date of Inspection	Discussed with (Signature)	Eddie	Inspected by (Signature)	Wanda Boutwell		
04/10/2012						
Next Inspection Due						
10/30/2012						
		Title: manager		Title: Environmental Health Specialist IV		

Georgia Department of Human Resources - Division of Public Health
TOURISTS ACCOMMODATION INSPECTION RECORD

Name of Accommodation	Address	City	County
Microtel	1728 Fountain CT	COLUMBUS	Muscogee
Number	Notes		
1:	n/a		
2:	n/a		
3:	No Available method for washing, rinsing, sanitizing multiuse utensils.		
10:	n/a		
11:	n/a		
15:	Veolia		
17:	Knox		
30:	n/a		
31:	n/a		
32:	n/a		